



SGS (TAIWAN) LTD.

Ultra Trace & Industrial Safety Hygiene

No.38, Wu Chyuan 7th Rd., New Taipei Industrial Park, New Taipei City, 24890, Taiwan

TEL : 02-22993279

FAX : 02-22981338

Gas Trace Report

Report No.: UO/2015/80150



Client : J-Material Co., Ltd.

Equipment Name : SPECIAL GAS CABINET

Model : JM-GC3-2 S/N : 20150001

Testing Dept. : SGS (TAIWAN) LTD.

Analyzer : John Lee & Sunny Liu

Sampling Date : 2015/08/14

Signed for and on behalf of
SGS Taiwan Ltd.

River Lee
Manager



NOTE: 1.The content of this report is invalid if it is not presented as the entire report.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.